



STEAM DRIP PAN ELBOW DETAIL

SCALE: NONE

NOTES FOR DESIGNER: (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)

1. WHEN EDITING DETAIL TO SUIT PROJECT, ADD JOB SPECIFIC REQUIREMENTS AND DELETE ONLY THOSE PORTIONS THAT DO NOT APPLY. TO SEEK A VARIANCE FROM APPLICABLE REQUIREMENTS, CONTACT THE ESM MECHANICAL POC.
2. KEEP LENGTH OF DISCHARGE PIPING TO A MINIMUM.
3. PIPE DISCHARGE PIPING THROUGH ROOF. TERMINATE 10 FEET ABOVE ROOF TO PREVENT ANY POTENTIAL PERSONNEL BURN HAZARDS.
4. REFER TO THE FOLLOWING LANL STANDARDS FOR ADDITIONAL REQUIREMENTS:
 - A. SPEC 15121, STEAM AND CONDENSATE SPECIALTIES.
 - B. SPEC 15181, STEAM AND CONDENSATE PIPING.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACKAGE).

1	8-13-03	U	REVISED TO COMPLY WITH DRAFTING MANUAL & REVISED DISCHARGE PIPING. DWG NO. WAS ST3204.	RP	RF	JM	GG	TO
NO	DATE	CLASS	DESCRIPTION	DWN	DSGN	CHKD	SUB	APP

**FACILITY & WASTE OPERATIONS
DESIGN ENGINEERING CONSTRUCTION SERVICES**

ENGINEERING STANDARDS MANUAL		DRAWN	R.PEARSON
		DESIGN	A.BRIDGE
		CHECKED	G.GREWAL
		DATE	6-28-99

BLDG X TA-X

STEAM DRIP PAN ELBOW DETAIL
1/2" - 1 1/2" SIZE

SUBMITTED DISCIPLINE POC: GURINDER GREWAL

APPROVED FOR RELEASE
STANDARDS MANAGER: TOBIN ORCH

SHEET 2 OF 2

Los Alamos NATIONAL LABORATORY PO Box 1663 Los Alamos, New Mexico 87545

CLASSIFICATION U REVIEWER LARRY BAYS DATE

PROJECT ID DRAWING NO CHAPTER 6 ST-D3020-4 REV 1